



THE SCHOOL DISTRICT OF
PHILADELPHIA

BOARD OF EDUCATION
Office of Capital Programs
440 North Broad Street, 3rd Floor – Suite 371
Philadelphia, PA 19130

TELEPHONE: (215) 400-4730

Addendum No. 4

Subject: BFHS / SLA Campus Summer 2020 Renovations General Construction, Mechanical, Plumbing, Electrical SDP Contract No. B-055C, B-056C, B-057C, B-058C of 2019/20

Location: Benjamin Franklin High School 548 N. Broad Street Philadelphia, Pennsylvania 19130

This Addendum, dated April 15, 2020, shall modify and become part of the Contract Documents. Any items not mentioned herein, or affected by, shall remain strictly in accordance with the original document.

Question 1: Stonshield SLT is listed as Basis of Design in the spec, but the Finish Schedule lists Dex-o-tex Quik Glaze which is basically a thin clear sealer applied over concrete whereas SLT is an 1/8" thick multi layered system with decorative quartz for texture. We assume you want the product noted on the drawing Finish Schedule; please confirm.

Response 1: Contractor is to disregard the resinous flooring listed in the finish schedule and proceed with the specification. Per specification section 097050-2.1-A, the basis of design is Décor Floor by Crossfield (Dex-O-Text). Stonhard and Dur-A-Flex are listed as acceptable alternative manufacturers.

End of Addendum #4