



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

June 21, 2022

Dear **Mifflin Elementary School** Community,

As part of the School District of Philadelphia's effort to provide students and staff with safe, accessible, and appealing drinking water, your school's water was tested for lead on **June 10, 2022**. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis. The action level used by the District is 10 parts per billion (ppb) of lead. If water exceeded this action level, the drinking water outlet was shut-off immediately and an action plan developed.

Federal studies indicate that children under the age of six are at the highest risk for harmful lead exposure, and children can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Philadelphia Department of Public Health (PDPH) recommends contacting your pediatrician or neighborhood Health Center for testing. Additionally, PDPH's lead hotline can address any health-related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call (215) 685-2788. For additional information about lead and children you can visit www.cdc.gov/lead.

There were **12** drinking water outlets tested at your school. Of those outlets, **12** outlets produced water that was below the action level of 10 ppb. **No** water outlets were found to have results above the water safety threshold.

The School District will test the drinking water at your school every five years and share the results through a letter and also post the results on the District's website. If you wish to review the results from your school and for more information, you may visit the District's website at: www.philasd.org/waterresults.

Sincerely,

Steve Link
Environmental Director



THE SCHOOL DISTRICT OF PHILADELPHIA

Operations Division

Office of Environmental Management and Services
440 North Broad Street
Philadelphia, Pennsylvania 19130
215-400-4750

Sample Date	Floor	Outlet Number	Outlet Type	Outlet Description	Lead Result (ppb)	PQL	Action Limits
06/10/2022	00	01	HS	In pre k RM 4	<1	1	BA
06/10/2022	00	04	HS	In RM 3	<1	1	BA
06/10/2022	00	07	HS	In hall outside faculty dining RM	<1	1	BA
06/10/2022	00	19	HS	Next to boiler RM	<1	1	BA
06/10/2022	00	20	HS	Next to boiler room - HS right	<1	1	BA
06/10/2022	01	32	HS	In hall next to maintenance closet	<1	1	BA
06/10/2022	01	35	HS	Inside room 102	<1	1	BA
06/10/2022	01	39	HS	Outside gym - HS left	<1	1	BA
06/10/2022	01	40	HS	Outside gym - HS right	<1	1	BA
06/10/2022	01	41	HS	Next to room 103	<1	1	BA
06/10/2022	02	42	HS	In hall across from stairs	<1	1	BA
06/10/2022	02	47	HS	Outside room 203	<1	1	BA

Notes:

AA = Above Action limit of 10 ppb
BA = Below Action limit of 10 ppb
MDL = Method Detection Limit
PQL = Practical Quantitation Limit
J = Result estimated below the PQL
< = not detected above PQL
ppb = parts per billion

Outlet Types:

WF = Water Fountain/Bubbler
HS = Hydration Station/Bottle Filling Station
FT = Faucet/Tap
FP = Food Prep/Pot-Filler/Kitchen Kettle
IM = Ice-Maker